

**ADDENDUM 2 TO BID DOCUMENTS FOR THE
LOST LAKE MARSH CREATION AND HYDROLOGIC RESTORATION
PROJECT (TE-72)**

TERREBONNE PARSH, LOUISIANA



**LOUISIANA COASTAL PROTECTION AND RESTORATION
AUTHORITY**

September 19, 2016

ADDENDUM 2 TO BID DOCUMENTS

LOST LAKE MARSH CREATION AND HYDROLOGIC RESTORATION PROJECT (TE-72)

This addendum shall be considered part of the Plans, Specifications, and Contract Documents (except as noted otherwise) and is issued to change, amplify, or delete from or otherwise explain these documents where provisions of this addendum differ from those of the original documents. This addendum shall have precedence over the original documents and shall govern.

Bidders shall acknowledge receipt of this addendum on the Louisiana Uniform Public Work Bid Form.

I. CPRA Responses to Bidder Questions

1. Question: Is there an estimated budget/cost?

Response: The Engineer's estimate of probable cost is \$25,013.938 for the base bid and \$1,718,928 for bid alternate 1.

2. Question: Is there an estimated start date for the work?

Response: The Owner shall submit a written Notice to Proceed to the Contractor which provides the starting date for the Contract Time. Furthermore, Louisiana Revised Statutes 38:2215.C states that "Upon the execution of the contract, the public entity, within thirty days thereafter, shall issue to the contractor a notice to proceed with the project. However, upon mutual consent by both parties, the notice to proceed may be extended."

3. Question: Are there any Union requirements associated with this bid?

Response: There are no union requirements associated with this bid.

4. Question: On Drawing sheet 23 of 61, the Engineer has specified a PMA22 Steel Sheet Piling for the structures in the above referenced solicitation. Upon requesting a quotation from a vendor for this pile section, we were informed that the PMA22 section is no longer manufactured. Please pass this information on to the designers so that an alternate section that is readily available can be specified.

Response: Sheet 23 – Note 5 will be modified as follows: The contractor may provide an equivalent to the steel sheet piling shape specified on this sheet. Steel sheet piles provided shall comply to technical specification TS-970. Flat (PS) sections are not allowed. The section provided shall meet the following minimum dimensions: 0.25 inch wall thickness; section modulus = 5.4 in³/ft of wall; and moment of inertia = 13.7 in⁴/ft of wall.

END OF ADDENDUM 2