

**ADDENDUM 2 TO BID DOCUMENTS FOR THE
BA-0002 & TE-0022 & TE0026 - SIGN REPLACEMENT & TE-0026
TIMBER CAP PILING REPLACEMENT PROJECT**

LAFOURCHE PARISH, LOUISIANA



**LOUISIANA COASTAL PROTECTION AND RESTORATION
AUTHORITY
JUNE 12, 2017**

**ADDENDUM NO. 2 TO BID DOCUMENTS FOR THE
BA-0002 & TE-0022 & TE0026 - SIGN REPLACEMENT & TE-0026
TIMBER CAP PILING REPLACEMENT PROJECT**

This addendum shall be considered part of the Plans, Specifications, and Contract Documents (except as noted otherwise) and is issued to change, amplify, or delete from or otherwise explain these documents where provisions of this addendum differ from those of the original documents. This addendum shall have precedence over the original documents and shall govern.

I. Question: In section TS-4.2, it states that each of the warning signs shall be fabricated from 1/4" thick steel plate or approved equal. In the past we have only used aluminum signs. Does this need to be clarified?

Answer: There are two completely different signs of completely different material. The signs on BA-0002 specified a 3/16th inch thick aluminum sign (page 3/12 of the plans) while the signs for TE-0022 specified a 1/4th inch thick steel plate sign (page 43 of the specs, section 4.2). This was intentionally specified to match the existing signs. Both must meet coast guard specifications. This is what should be bid on.